

Cylinder Filling Check List

I understand that the following items have been checked and/or performed on my cylinder(s):

- Cylinder has only been used in propane service
- Cylinder is clearly marked and labeled
- Cylinder requalification date is still valid
- Cylinder is free of serious dents, leaks, cracks, bulging, defective valves, evidence of physical abuse, fire or heat damage, excessive rusting or corrosion, damage to valves and foot rings
- Cylinder is leak free
- Valves are protected with a cap or collar
- Valve outlet was capped or plugged
- If consumer was in an enclosed bodied vehicle, I did not fill cylinders totaling more than 90lbs. of LP Gas and no single cylinder had a capacity of more than 45lbs.
- Pressure relief valve communicates directly with the vapor space of the container

Customer Signature

Company Representative

Date: _____

Cylinder Filling Check List

I understand that the following items have been checked and/or performed on my cylinder(s):

- Cylinder has only been used in propane service
- Cylinder is clearly marked and labeled
- Cylinder requalification date is still valid
- Cylinder is free of serious dents, leaks, cracks, bulging, defective valves, evidence of physical abuse, fire or heat damage, excessive rusting or corrosion, damage to valves and foot rings
- Cylinder is leak free
- Valves are protected with a cap or collar
- Valve outlet was capped or plugged
- If consumer was in an enclosed bodied vehicle, I did not fill cylinders totaling more than 90lbs. of LP Gas and no single cylinder had a capacity of more than 45lbs.
- Pressure relief valve communicates directly with the vapor space of the container

Customer Signature

Company Representative

Date: _____